



METER REQUEST APPLICATION IRRIGATION

Meter Rating:

Size	GPM
3/4"	24
1"	40
1-1/2"	80
2"	128
3"	400
4"	800
6"	1,600
8"	2,720
10"	4,000

1. Are Property Taxes assessed on this parcel? Y/N

A water meter shall be sized to ensure that the maximum demand (in gallons per minute) will not exceed 80% of the manufacturer's recommended maximum flow rate, as shown in Section 27.03. In no case shall the water meter size be less than 3/4-inch.

Backflow Prevention Details are located at www.sdwas.com

OWNER INFORMATION

Company Name:

Contact Name:

Contact E-Mail Address:

Company Address:

City:

State:

ZIP Code:

Phone:

Fax:

Cellular:

***Who is financially responsible for payment of the monthly water bill?
(circle one) OWNER APPLICANT**

APPLICANT INFORMATION

Company Name:

Contact Name:

Contact E-Mail Address:

Company Address:

City:

State:

ZIP Code:

Phone:

Fax:

Cellular:

PROJECT INFORMATION

Project Name:

Project Number:

Service Address:

City:

State:

ZIP Code:

POC:

Irr Sq. Ft.:

Station:

Lateral Size:

Meter Size:

POC:

Irr Sq. Ft.:

Station:

Lateral Size:

Meter Size:

POC:

Irr Sq. Ft.:

Station:

Lateral Size:

Meter Size:

Signature of Applicant:

Date: